

ENTERED

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W. 39969

UNIQUE WELL I.D. # 33/1/27M

Water Right Permit No. 33/1/27M

(1) OWNER: Name George Lambert Address 2300 Oldenburg Ln. Oak Harbor WA.

(2) LOCATION OF WELL: County ISLAND NW 1/4 SW 1/4 Sec 27 T. 33 N. R. 15 W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) 1150 W. HELLER RD, OAK HARBOR WA. 98277

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (If more than one) 2  
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☒ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 240 feet. Depth of completed well 240 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 Diam. from 0 ft. to 235 ft.  
Welded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Liner installed ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒

Type of perforator used \_\_\_\_\_

SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK

Type STAINLESS

Model No. \_\_\_\_\_

Diam. 6 Slot size 25 from 235 ft. to 240 ft.

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒

Size of gravel \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation above mean sea level 200 - ft.  
Static level 186 ft. below top of well Date 6-94  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Artesian water is controlled by \_\_\_\_\_ (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made? Yes ☒ No ☐ If yes, by whom? Bob Pumps  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

" " " "  
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Date of test \_\_\_\_\_

Bailer test 10 gal./min. with 30 - ft. drawdown after 2 hrs.

Airtest \_\_\_\_\_ gal./min. with stem set at \_\_\_\_\_ ft. for \_\_\_\_\_ hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
CLAY	0	20
HARD PAN	20	28
CLAY	28	84
SAND	84	138
SANDY CLAY	138	235
WATER GRAVEL mix	235	240
CLAY	240	

RECEIVED

JUN 20 1994

DEPT. OF ECOLOGY

Work Started June, 1994 Completed June 17, 1994

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WHIDBEY WELL DRILLERS  
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address OAK HARBOR WA.

(Sign) Dennis Jahn License No. 129  
(WELL DRILLER)

Contractor's Registration W0110DUP2EF M/T Date June, 1994

(USE ADDITIONAL SHEETS IF NECESSARY)

